

Delp G040 +4
for
Delp G040 +4

Dec 31, 2022 - Jan 31, 2023

Author: Miranda Wright
mwright15@kumc.edu

Review & approval records location:

Summary Report "Delp G040 +4" for Delp G040 +4

Dec 31, 2022 - Jan 31, 2023

MACHINE DETAILS


Serial Number: **6077715FD487**
Location: **Unknown**
Description: **6077715FD487**
Installation date:

EQUIPMENT DETAILS

Category: **Unknown**
Manufacturer:
Model:
Service Entered Date:

TEMPERATURE

AVG: **-6.22 °C** | MIN: **-9.06 °C** | MAX: **-0.71 °C**



DATA LOGS

CENTRAL TIME (US & CANADA)	TEMPERATURE (°C)
2022-12-30 6:00 AM	-4.81°C
2022-12-31 6:00 AM	-4.09°C
2023-01-01 6:00 AM	-4.41°C
2023-01-02 6:00 AM	-4.34°C
2023-01-03 6:00 AM	-4.66°C
2023-01-04 6:00 AM	-4.85°C
2023-01-05 6:00 AM	-5.74°C
2023-01-06 6:00 AM	-6.66°C
2023-01-07 6:00 AM	-5.4°C
2023-01-08 6:00 AM	-4.78°C
2023-01-09 6:00 AM	-5.27°C
2023-01-10 6:00 AM	-5.72°C
2023-01-11 6:00 AM	-5.84°C
2023-01-12 6:00 AM	-5.87°C
2023-01-13 6:00 AM	-6.55°C
2023-01-14 6:00 AM	-5.64°C
2023-01-15 6:00 AM	-4.59°C
2023-01-16 6:00 AM	-4.86°C
2023-01-17 6:00 AM	-5.1°C
2023-01-18 6:00 AM	-5.83°C
2023-01-19 6:00 AM	-5.59°C
2023-01-20 6:00 AM	-6.27°C
2023-01-21 6:00 AM	-5.47°C
2023-01-22 6:00 AM	-4.53°C
2023-01-23 6:00 AM	-5.2°C
2023-01-24 6:00 AM	-6.23°C
2023-01-25 6:00 AM	-6.34°C
2023-01-26 6:00 AM	-7.02°C
2023-01-27 6:00 AM	-6.93°C
2023-01-28 6:00 AM	-5.77°C
2023-01-29 6:00 AM	-4.94°C

CENTRAL TIME (US & CANADA)

TEMPERATURE (°C)

2023-01-30 6:00 AM

-6.77°C

ALERTS

No Alert Events for selected date range.

Delp G040 +4
for
Delp G040 +4

Jan 28, 2023 - Feb 28, 2023

Author: Miranda Wright
mwright15@kumc.edu

Review & approval records location:

Summary Report "Delp G040 +4" for Delp G040 +4

Jan 28, 2023 - Feb 28, 2023


MACHINE DETAILS

Serial Number: 6077715FD487
Location: Unknown
Description: 6077715FD487
Installation date:

EQUIPMENT DETAILS

Category: Unknown
Manufacturer:
Model:
Service Entered Date:

TEMPERATURE AVG: -6.51 °C | MIN: -9.18 °C | MAX: -0.38 °C



Timezone: Central Time (US & Canada) (CST)

● Temperature (°C)

DATA LOGS

CENTRAL TIME (US & CANADA)	TEMPERATURE (°C)
2023-01-27 6:00 AM	-6.46°C
2023-01-28 6:00 AM	-5.77°C
2023-01-29 6:00 AM	-4.94°C
2023-01-30 6:00 AM	-6.77°C
2023-01-31 6:00 AM	-7.41°C
2023-02-01 6:00 AM	-7.21°C
2023-02-02 6:00 AM	-6.95°C
2023-02-03 6:00 AM	-7.45°C
2023-02-04 6:00 AM	-6.02°C
2023-02-05 6:00 AM	-4.37°C
2023-02-06 6:00 AM	-4.8°C
2023-02-07 6:00 AM	-5.66°C
2023-02-08 6:00 AM	-5.89°C
2023-02-09 6:00 AM	-6.09°C
2023-02-10 6:00 AM	-6.45°C
2023-02-11 6:00 AM	-6.34°C
2023-02-12 6:00 AM	-5.37°C
2023-02-13 6:00 AM	-5.27°C
2023-02-14 6:00 AM	-5.88°C
2023-02-15 6:00 AM	-5.96°C
2023-02-16 6:00 AM	-6.19°C
2023-02-17 6:00 AM	-7.09°C
2023-02-18 6:00 AM	-5.6°C
2023-02-19 6:00 AM	-4.52°C
2023-02-20 6:00 AM	-4.74°C
2023-02-21 6:00 AM	-5.64°C
2023-02-22 6:00 AM	-6.3°C
2023-02-23 6:00 AM	-5.7°C
2023-02-24 6:00 AM	-6.88°C
2023-02-25 6:00 AM	-6.62°C
2023-02-26 6:00 AM	-5.32°C
2023-02-27 6:00 AM	-5.23°C

THRESHOLD ALERTS

No Alert Events for selected date range.

CONNECTION ALERTS

No Alert Events for selected date range.

POWER ALERTS

CENTRAL TIME (US & CANADA)	MACHINE NAME	TYPE	RULE	LAST READING	ACTIVITY
2023-02-21 8:05 AM	Delp G040 +4	Power	Delp G040 Power Alert	100% Battery	Alert Cleared
			Notification:Email sent to Luigi Boccardi, Miranda Wright. Message:Delp G040 +4 has fresh batteries. Alert Rule:Delp G040 Power Alert		
			Message:Delp G040 +4 has fresh batteries. Alert Rule:Delp G040 Power Alert		
			Notification:Email sent to Luigi Boccardi, Miranda Wright. Message:Delp G040 +4 still has less than 10% battery remaining. Please replace the batteries with fresh AAA Lithium batteries now. Alert Rule:Delp G040 Power Alert		
			Message:Delp G040 +4 has less then 10% battery remaining. Please replace the batteries with fresh AAA Lithium batteries now. Alert Rule:Delp G040 Power Alert		
			Notification:Email sent to Luigi Boccardi, Miranda Wright. Message:Delp G040 +4 has less than 10% battery remaining. Please replace the batteries with fresh AAA Lithium batteries now. Alert Rule:Delp G040 Power Alert		
			Message:Delp G040 +4 has less then 10% battery remaining. Please replace the batteries with fresh AAA Lithium batteries now. Alert Rule:Delp G040 Power Alert		
2023-02-21 7:46 AM	Delp G040 +4	Power	Copy of Power Alert for All Element-A, Element-T and Gateways 4	100% Battery	Alert Cleared

CENTRAL TIME (US & CANADA)	MACHINE NAME	TYPE	RULE	LAST READING	ACTIVITY
			Notification:Email and SMS sent to Miranda Wright.		
	2023-02-21 7:46 AM		Message:Delp G040 +4 has fresh batteries.		
			Alert Rule:Copy of Power Alert for All Element-A, Element-T and Gateways 4		
			Message:Delp G040 +4 has fresh batteries.		
	2023-02-21 7:46 AM		Alert Rule:Copy of Power Alert for All Element-A, Element-T and Gateways 4		
			Message:Alert Released by Miranda Wright		
	2023-02-21 7:42 AM		Alert Rule:Copy of Power Alert for All Element-A, Element-T and Gateways 4		
			Message:Alert Claimed by Miranda Wright		
	2023-02-21 7:42 AM		Alert Rule:Copy of Power Alert for All Element-A, Element-T and Gateways 4		
			Notification:Email and SMS sent to Miranda Wright.		
	2023-02-20 9:44 PM		Message:Delp G040 +4 still has less than 10% battery remaining. Please replace the batteries with fresh AAA Lithium batteries now.		
			Alert Rule:Copy of Power Alert for All Element-A, Element-T and Gateways 4		
			Message:Delp G040 +4 has less then 10% battery remaining. Please replace the batteries with fresh AAA Lithium batteries now.		
	2023-02-20 9:44 PM		Alert Rule:Copy of Power Alert for All Element-A, Element-T and Gateways 4		
			Notification:Email and SMS sent to Miranda Wright.		
	2023-02-13 9:40 PM		Message:Delp G040 +4 has less than 10% battery remaining. Please replace the batteries with fresh AAA Lithium batteries now.		
			Alert Rule:Copy of Power Alert for All Element-A, Element-T and Gateways 4		
			Message:Delp G040 +4 has less then 10% battery remaining. Please replace the batteries with fresh AAA Lithium batteries now.		
	2023-02-13 9:40 PM		Alert Rule:Copy of Power Alert for All Element-A, Element-T and Gateways 4		

ERROR ALERTS

No Alert Events for selected date range.

Delp G040 +4
for
Delp G040 +4

Feb 28, 2023 - Mar 31, 2023

Author: Miranda Wright
mwright15@kumc.edu

Review & approval records location:

Summary Report "Delp G040 +4" for Delp G040 +4

Feb 28, 2023 - Mar 31, 2023

MACHINE DETAILS


Serial Number: **6077715FD487**
Location: **Unknown**
Description: **6077715FD487**
Installation date:

EQUIPMENT DETAILS

Category: **Unknown**
Manufacturer:
Model:
Service Entered Date:

TEMPERATURE

AVG: **-6.93 °C** | MIN: **-12.12 °C** | MAX: **2.67 °C**



DATA LOGS

CENTRAL TIME (US & CANADA)	TEMPERATURE (°C)
2023-02-27 5:00 AM	-6.01°C
2023-02-28 5:00 AM	-5.55°C
2023-03-01 5:00 AM	-5.47°C
2023-03-02 5:00 AM	-5.5°C
2023-03-03 5:00 AM	-5.95°C
2023-03-04 5:00 AM	-5.1°C
2023-03-05 5:00 AM	-3.5°C
2023-03-06 5:00 AM	-3.63°C
2023-03-07 5:00 AM	-5.06°C
2023-03-08 5:00 AM	-4.95°C
2023-03-09 5:00 AM	-5.5°C
2023-03-10 5:00 AM	-5.66°C
2023-03-11 5:00 AM	-5°C
2023-03-12 5:00 AM	-3.95°C
2023-03-13 5:00 AM	-4.96°C
2023-03-14 5:00 AM	-6.13°C
2023-03-15 5:00 AM	-5.66°C
2023-03-16 5:00 AM	-4.89°C
2023-03-17 5:00 AM	-5.83°C
2023-03-18 5:00 AM	-5.88°C
2023-03-19 5:00 AM	-5.54°C
2023-03-20 5:00 AM	-5.06°C
2023-03-21 5:00 AM	-5.09°C
2023-03-22 5:00 AM	-4.7°C
2023-03-23 5:00 AM	-6.24°C
2023-03-24 5:00 AM	-10.12°C
2023-03-25 5:00 AM	-9.52°C
2023-03-26 5:00 AM	-8.9°C
2023-03-27 5:00 AM	-9.44°C
2023-03-28 5:00 AM	-10.09°C
2023-03-29 5:00 AM	-10.3°C

CENTRAL TIME (US & CANADA)

TEMPERATURE (°C)

2023-03-30 5:00 AM

-7.41°C

ALERTS

No Alert Events for selected date range.

Delp G040 +4
for
Delp G040 +4

Mar 30, 2023 - Apr 30, 2023

Author: Miranda Wright
mwright15@kumc.edu

Review & approval records location:

Summary Report "Delp G040 +4" for Delp G040 +4

Mar 30, 2023 - Apr 30, 2023

MACHINE DETAILS


Serial Number: **6077715FD487**
Location: **Unknown**
Description: **6077715FD487**
Installation date:

EQUIPMENT DETAILS

Category: **Unknown**
Manufacturer:
Model:
Service Entered Date:

TEMPERATURE

AVG: **-4.93 °C** | MIN: **-10.92 °C** | MAX: **2.45 °C**



DATA LOGS

CENTRAL TIME (US & CANADA)	TEMPERATURE (°C)
2023-03-29 5:00 AM	-7.05°C
2023-03-30 5:00 AM	-7.41°C
2023-03-31 5:00 AM	-8.77°C
2023-04-01 5:00 AM	-7.95°C
2023-04-02 5:00 AM	-6.92°C
2023-04-03 5:00 AM	-7.73°C
2023-04-04 5:00 AM	-7.7°C
2023-04-05 5:00 AM	-3.12°C
2023-04-06 5:00 AM	-3.26°C
2023-04-07 5:00 AM	-3.66°C
2023-04-08 5:00 AM	-3.09°C
2023-04-09 5:00 AM	-2.72°C
2023-04-10 5:00 AM	-2.3°C
2023-04-11 5:00 AM	-3.11°C
2023-04-12 5:00 AM	-4.19°C
2023-04-13 5:00 AM	-4.01°C
2023-04-14 5:00 AM	-4.23°C
2023-04-15 5:00 AM	-3.72°C
2023-04-16 5:00 AM	-3.45°C
2023-04-17 5:00 AM	-2.99°C
2023-04-18 5:00 AM	-3.82°C
2023-04-19 5:00 AM	-4.11°C
2023-04-20 5:00 AM	-4.62°C
2023-04-21 5:00 AM	-3.66°C
2023-04-22 5:00 AM	-3.72°C
2023-04-23 5:00 AM	-3.03°C
2023-04-24 5:00 AM	-4.77°C
2023-04-25 5:00 AM	-4.91°C
2023-04-26 5:00 AM	-4.33°C
2023-04-27 5:00 AM	-3.84°C
2023-04-28 5:00 AM	-3.55°C

CENTRAL TIME (US & CANADA)

TEMPERATURE (°C)

2023-04-29 5:00 AM

-3.23°C

ALERTS

No Alert Events for selected date range.

Delp G040 +4
for
Delp G040 +4

May 01, 2023 - Jun 01, 2023

Author: Miranda Wright
mwright15@kumc.edu

Review & approval records location:

Summary Report "Delp G040 +4" for Delp G040 +4

May 01, 2023 - Jun 01, 2023

MACHINE DETAILS


Serial Number: **6077715FD487**
Location: **Unknown**
Description: **6077715FD487**
Installation date:

EQUIPMENT DETAILS

Category: **Unknown**
Manufacturer:
Model:
Service Entered Date:

TEMPERATURE

AVG: **-0.61 °C** | MIN: **-6.33 °C** | MAX: **10.55 °C**



DATA LOGS

CENTRAL TIME (US & CANADA)	TEMPERATURE (°C)
2023-04-30 5:00 AM	-2.56°C
2023-05-01 5:00 AM	-2.95°C
2023-05-02 5:00 AM	-4.01°C
2023-05-03 5:00 AM	-5.38°C
2023-05-04 5:00 AM	-4.46°C
2023-05-05 5:00 AM	-3.52°C
2023-05-06 5:00 AM	-3.19°C
2023-05-07 5:00 AM	-2.93°C
2023-05-08 5:00 AM	-3.07°C
2023-05-09 5:00 AM	-3.96°C
2023-05-10 5:00 AM	-2.03°C
2023-05-11 5:00 AM	-1.41°C
2023-05-12 5:00 AM	-0.87°C
2023-05-13 5:00 AM	-0.04°C
2023-05-14 5:00 AM	-0.53°C
2023-05-15 5:00 AM	-1.76°C
2023-05-16 5:00 AM	-0.27°C
2023-05-17 5:00 AM	-0.48°C
2023-05-18 5:00 AM	-0.91°C
2023-05-19 5:00 AM	-0.26°C
2023-05-20 5:00 AM	0.2°C
2023-05-21 5:00 AM	0.44°C
2023-05-22 5:00 AM	-0.57°C
2023-05-23 5:00 AM	-2.08°C
2023-05-24 5:00 AM	-1.87°C
2023-05-25 5:00 AM	-1.7°C
2023-05-26 5:00 AM	-1.83°C
2023-05-27 5:00 AM	-0.34°C
2023-05-28 5:00 AM	-0.41°C
2023-05-29 5:00 AM	0.05°C
2023-05-30 5:00 AM	-1.26°C

CENTRAL TIME (US & CANADA)

TEMPERATURE (°C)

2023-05-31 5:00 AM

-1.16°C

ALERTS

No Alert Events for selected date range.

Delp G040 +4
for
Delp G040 +4

Jun 01, 2023 - Jul 01, 2023

Author: Miranda Wright
mwright15@kumc.edu

Review & approval records location:

Summary Report "Delp G040 +4" for Delp G040 +4

Jun 01, 2023 - Jul 01, 2023

MACHINE DETAILS


Serial Number: **6077715FD487**
Location: **Unknown**
Description: **6077715FD487**
Installation date:

EQUIPMENT DETAILS

Category: **Unknown**
Manufacturer:
Model:
Service Entered Date:

TEMPERATURE

AVG: **2.09 °C** | MIN: **-3.84 °C** | MAX: **22.42 °C**



DATA LOGS

CENTRAL TIME (US & CANADA)	TEMPERATURE (°C)
2023-05-31 5:00 AM	4.49 °C
2023-06-01 5:00 AM	0.61 °C
2023-06-02 5:00 AM	-1.69 °C
2023-06-03 5:00 AM	-0.7 °C
2023-06-04 5:00 AM	0.08 °C
2023-06-05 5:00 AM	-1.33 °C
2023-06-06 5:00 AM	-1.77 °C
2023-06-07 5:00 AM	-2.08 °C
2023-06-08 5:00 AM	-2.22 °C
2023-06-09 5:00 AM	-1.79 °C
2023-06-10 5:00 AM	-0.17 °C
2023-06-11 5:00 AM	0.45 °C
2023-06-12 5:00 AM	-0.56 °C
2023-06-13 5:00 AM	-1.54 °C
2023-06-14 5:00 AM	-1.79 °C
2023-06-15 5:00 AM	0.12 °C
2023-06-16 5:00 AM	-1.2 °C
2023-06-17 5:00 AM	1.98 °C
2023-06-18 5:00 AM	0.98 °C
2023-06-19 5:00 AM	-0.62 °C
2023-06-20 5:00 AM	6.32 °C
2023-06-21 5:00 AM	5.88 °C
2023-06-22 5:00 AM	5.54 °C
2023-06-23 5:00 AM	8.52 °C
2023-06-24 5:00 AM	6.88 °C
2023-06-25 5:00 AM	8.95 °C
2023-06-26 5:00 AM	4.74 °C
2023-06-27 5:00 AM	6.66 °C
2023-06-28 5:00 AM	8.38 °C
2023-06-29 5:00 AM	7.96 °C
2023-06-30 5:00 AM	7.54 °C

THRESHOLD ALERTS

CENTRAL TIME (US & CANADA)	MACHINE NAME	TYPE	RULE	LAST READING	LIMITS (H/L)	ACTIVITY
2023-06-01 12:03 PM	Delp G040 +4	Temperature	Copy of Threshold Alert for Element-T 4	8.97 °C	10.0/-100.0 °C	Alert Cleared
			Notification:Email and SMS sent to Miranda Wright.			
	2023-06-01 12:03 PM		Message:Delp G040 +4 is reporting Temperature of 8.97 °C, within the limit of -100.0 °C to 10.0 °C.			
			Alert Rule:Copy of Threshold Alert for Element-T 4			
	2023-06-01 12:03 PM		Message:Temperature Clear: 8.97 °C, within the limit of -100.0 °C to 10.0 °C			
			Alert Rule:Copy of Threshold Alert for Element-T 4			
	2023-06-01 11:28 AM		Notification:Email and SMS sent to Miranda Wright.			
			Message:Delp G040 +4 is reporting Temperature of 13.32 °C, still above the limit of 10.0 °C.			
			Alert Rule:Copy of Threshold Alert for Element-T 4			
	2023-06-01 11:28 AM		Message:Temperature Alert: 13.32 °C, above the limit of 10.0 °C			
			Alert Rule:Copy of Threshold Alert for Element-T 4			
	2023-06-01 11:23 AM		Notification:Email and SMS sent to Miranda Wright.			
			Message:Delp G040 +4 is reporting Temperature of 13.92 °C, still above the limit of 10.0 °C.			
			Alert Rule:Copy of Threshold Alert for Element-T 4			
	2023-06-01 11:23 AM		Message:Temperature Alert: 13.92 °C, above the limit of 10.0 °C			
			Alert Rule:Copy of Threshold Alert for Element-T 4			
	2023-06-01 11:17 AM		Notification:Email and SMS sent to Miranda Wright.			
			Message:Delp G040 +4 is reporting Temperature of 14.69 °C, above the limit of 10.0 °C.			
			Alert Rule:Copy of Threshold Alert for Element-T 4			
	2023-06-01 11:17 AM		Message:Temperature Alert: 14.69 °C, above the limit of 10.0 °C			
			Alert Rule:Copy of Threshold Alert for Element-T 4			
2023-06-01 12:02 PM	Delp G040 +4	Temperature	4 Degree Threshold Alert	8.97 °C	10.0/-100.0 °C	Alert Cleared

CENTRAL TIME (US & CANADA)	MACHINE NAME	TYPE	RULE	LAST READING	LIMITS (H/L)	ACTIVITY
						Notification:Email sent to Miranda Wright.
	2023-06-01 12:02 PM					Message:Delp G040 +4 is reporting Temperature of 8.97 °C, within the limit of -100.0 °C to 10.0 °C. Alert Rule:4 Degree Threshold Alert
	2023-06-01 12:02 PM					Message:Temperature Clear: 8.97 °C, within the limit of -100.0 °C to 10.0 °C Alert Rule:4 Degree Threshold Alert
						Notification:Email sent to Miranda Wright.
	2023-06-01 11:38 AM					Message:Delp G040 +4 is reporting Temperature of 12.48 °C, still above the limit of 10.0 °C. Alert Rule:4 Degree Threshold Alert
	2023-06-01 11:38 AM					Message:Temperature Alert: 12.48 °C, above the limit of 10.0 °C Alert Rule:4 Degree Threshold Alert
						Notification:Email sent to Miranda Wright.
	2023-06-01 11:17 AM					Message:Delp G040 +4 is reporting Temperature of 14.63 °C, above the limit of 10.0 °C. Alert Rule:4 Degree Threshold Alert
	2023-06-01 11:17 AM					Message:Temperature Alert: 14.63 °C, above the limit of 10.0 °C Alert Rule:4 Degree Threshold Alert

CONNECTION ALERTS

CENTRAL TIME (US & CANADA)	MACHINE NAME	TYPE	RULE	LAST READING	ACTIVITY
2023-06-12 3:48 PM	Delp G040 +4	Connection	Delp G040 Connection Alert	Connected	Alert Cleared
			Notification:Email sent to Luigi Boccardi, Miranda Wright. Message:Delp G040 +4 has restored wireless connection to the Elemental Gateway. Alert Rule:Delp G040 Connection Alert		
			Message:Delp G040 +4 has restored wireless connection to the Elemental Gateway. Alert Rule:Delp G040 Connection Alert		
			Notification:Email sent to Luigi Boccardi, Miranda Wright. Message:Delp G040 +4 has lost wireless connection to the Elemental Gateway. Alert Rule:Delp G040 Connection Alert		
			Message:Delp G040 +4 has lost wireless connection to the Elemental Gateway. Alert Rule:Delp G040 Connection Alert		
2023-06-12 3:48 PM	Delp G040 +4	Connection	Copy of Connection Alert for All Element-A, Element-T and Gateways 4	Connected	Alert Cleared

			Notification:Email sent to Miranda Wright. Message:Delp G040 +4 has restored wireless connection to the Elemental Gateway. Alert Rule:Copy of Connection Alert for All Element-A, Element-T and Gateways 4		
			Message:Delp G040 +4 has restored wireless connection to the Elemental Gateway. Alert Rule:Copy of Connection Alert for All Element-A, Element-T and Gateways 4		

			Notification:Email sent to Miranda Wright. Message:Delp G040 +4 has lost wireless connection to the Elemental Gateway. Alert Rule:Copy of Connection Alert for All Element-A, Element-T and Gateways 4		
			Message:Delp G040 +4 has lost wireless connection to the Elemental Gateway. Alert Rule:Copy of Connection Alert for All Element-A, Element-T and Gateways 4		

POWER ALERTS

No Alert Events for selected date range.

ERROR ALERTS

No Alert Events for selected date range.

Delp G040 +4
for
Delp G040 +4

Jul 01, 2023 - Aug 01, 2023

Author: Miranda Wright
mwright15@kumc.edu

Review & approval records location:

Summary Report "Delp G040 +4" for Delp G040 +4

Jul 01, 2023 - Aug 01, 2023

MACHINE DETAILS


Serial Number: **6077715FD487**
Location: **Unknown**
Description: **6077715FD487**
Installation date:

EQUIPMENT DETAILS

Category: **Unknown**
Manufacturer:
Model:
Service Entered Date:

TEMPERATURE

AVG: **6.64 °C** | MIN: **3.15 °C** | MAX: **13.61 °C**



DATA LOGS

CENTRAL TIME (US & CANADA)	TEMPERATURE (°C)
2023-06-30 5:00 AM	6.72°C
2023-07-01 5:00 AM	7.22°C
2023-07-02 5:00 AM	5.63°C
2023-07-03 5:00 AM	7.69°C
2023-07-04 5:00 AM	7.85°C
2023-07-05 5:00 AM	5.32°C
2023-07-06 5:00 AM	4.91°C
2023-07-07 5:00 AM	4.62°C
2023-07-08 5:00 AM	9.34°C
2023-07-09 5:00 AM	5.18°C
2023-07-10 5:00 AM	5.1°C
2023-07-11 5:00 AM	6.68°C
2023-07-12 5:00 AM	7.91°C
2023-07-13 5:00 AM	6.13°C
2023-07-14 5:00 AM	7.69°C
2023-07-15 5:00 AM	6.57°C
2023-07-16 5:00 AM	9.07°C
2023-07-17 5:00 AM	4.83°C
2023-07-18 5:00 AM	4.82°C
2023-07-19 5:00 AM	6.7°C
2023-07-20 5:00 AM	8.9°C
2023-07-21 5:00 AM	4.6°C
2023-07-22 5:00 AM	8.96°C
2023-07-23 5:00 AM	5.34°C
2023-07-24 5:00 AM	7.16°C
2023-07-25 5:00 AM	4.2°C
2023-07-26 5:00 AM	5.79°C
2023-07-27 5:00 AM	3.73°C
2023-07-28 5:00 AM	7.12°C
2023-07-29 5:00 AM	5.23°C
2023-07-30 5:00 AM	9.02°C

CENTRAL TIME (US & CANADA)

TEMPERATURE (°C)

2023-07-31 5:00 AM

4.06°C

ALERTS

No Alert Events for selected date range.

Delp G040 +4
for
Delp G040 +4

Aug 01, 2023 - Sep 01, 2023

Author: Miranda Wright
mwright15@kumc.edu

Review & approval records location:

Summary Report "Delp G040 +4" for Delp G040 +4

Aug 01, 2023 - Sep 01, 2023

MACHINE DETAILS


Serial Number: **6077715FD487**
Location: **Unknown**
Description: **6077715FD487**
Installation date:

EQUIPMENT DETAILS

Category: **Unknown**
Manufacturer:
Model:
Service Entered Date:

TEMPERATURE

AVG: **6.63 °C** | MIN: **3.15 °C** | MAX: **16.22 °C**



DATA LOGS

CENTRAL TIME (US & CANADA)	TEMPERATURE (°C)
2023-07-31 5:00 AM	4.74°C
2023-08-01 5:00 AM	6.34°C
2023-08-02 5:00 AM	7.25°C
2023-08-03 5:00 AM	3.79°C
2023-08-04 5:00 AM	5.51°C
2023-08-05 5:00 AM	5.22°C
2023-08-06 5:00 AM	5.1°C
2023-08-07 5:00 AM	7.98°C
2023-08-08 5:00 AM	4.8°C
2023-08-09 5:00 AM	6.14°C
2023-08-10 5:00 AM	6.23°C
2023-08-11 5:00 AM	8.77°C
2023-08-12 5:00 AM	7.98°C
2023-08-13 5:00 AM	4.83°C
2023-08-14 5:00 AM	7.47°C
2023-08-15 5:00 AM	7.25°C
2023-08-16 5:00 AM	6.41°C
2023-08-17 5:00 AM	6.41°C
2023-08-18 5:00 AM	6.04°C
2023-08-19 5:00 AM	7.25°C
2023-08-20 5:00 AM	7.73°C
2023-08-21 5:00 AM	6.88°C
2023-08-22 5:00 AM	4.41°C
2023-08-23 5:00 AM	8.15°C
2023-08-24 5:00 AM	6.23°C
2023-08-25 5:00 AM	8.4°C
2023-08-26 5:00 AM	7.56°C
2023-08-27 5:00 AM	8.99°C
2023-08-28 5:00 AM	4.91°C
2023-08-29 5:00 AM	7.84°C
2023-08-30 5:00 AM	4.39°C
2023-08-31 5:00 AM	8.76°C

THRESHOLD ALERTS

No Alert Events for selected date range.

CONNECTION ALERTS

CENTRAL TIME (US & CANADA)	MACHINE NAME	TYPE	RULE	LAST READING	ACTIVITY
2023-08-26 4:24 PM	Delp G040 +4	Connection	Delp G040 Connection Alert	Connected	Alert Cleared
			Notification:Email sent to Luigi Boccardi, Miranda Wright. Message:Delp G040 +4 has restored wireless connection to the Elemental Gateway. Alert Rule:Delp G040 Connection Alert		
			Message:Delp G040 +4 has restored wireless connection to the Elemental Gateway. Alert Rule:Delp G040 Connection Alert		
			Notification:Email sent to Luigi Boccardi, Miranda Wright. Message:Delp G040 +4 has lost wireless connection to the Elemental Gateway. Alert Rule:Delp G040 Connection Alert		
			Message:Delp G040 +4 has lost wireless connection to the Elemental Gateway. Alert Rule:Delp G040 Connection Alert		

2023-08-26 4:24 PM Delp G040 +4 Connection **Copy of Connection Alert for All Element-A, Element-T and Gateways 4** Connected Alert Cleared

			Notification:Email sent to Miranda Wright. Message:Delp G040 +4 has restored wireless connection to the Elemental Gateway. Alert Rule:Copy of Connection Alert for All Element-A, Element-T and Gateways 4		
			Message:Delp G040 +4 has restored wireless connection to the Elemental Gateway. Alert Rule:Copy of Connection Alert for All Element-A, Element-T and Gateways 4		

			Notification:Email sent to Miranda Wright. Message:Delp G040 +4 has lost wireless connection to the Elemental Gateway. Alert Rule:Copy of Connection Alert for All Element-A, Element-T and Gateways 4		
			Message:Delp G040 +4 has lost wireless connection to the Elemental Gateway. Alert Rule:Copy of Connection Alert for All Element-A, Element-T and Gateways 4		

POWER ALERTS

No Alert Events for selected date range.

ERROR ALERTS

No Alert Events for selected date range.

Delp G040 +4
for
Delp G040 +4

Sep 01, 2023 - Oct 01, 2023

Author: Miranda Wright
mwright15@kumc.edu

Review & approval records location:

Summary Report "Delp G040 +4" for Delp G040 +4

Sep 01, 2023 - Oct 01, 2023

MACHINE DETAILS


Serial Number: **6077715FD487**
Location: **Unknown**
Description: **6077715FD487**
Installation date:

EQUIPMENT DETAILS

Category: **Unknown**
Manufacturer:
Model:
Service Entered Date:

TEMPERATURE

AVG: **6.67 °C** | MIN: **2.63 °C** | MAX: **12.2 °C**



DATA LOGS

CENTRAL TIME (US & CANADA)	TEMPERATURE (°C)
2023-08-31 5:00 AM	8.97°C
2023-09-01 5:00 AM	5.49°C
2023-09-02 5:00 AM	7.89°C
2023-09-03 5:00 AM	8.45°C
2023-09-04 5:00 AM	8.4°C
2023-09-05 5:00 AM	7.3°C
2023-09-06 5:00 AM	9.17°C
2023-09-07 5:00 AM	6.91°C
2023-09-08 5:00 AM	4.08°C
2023-09-09 5:00 AM	6.29°C
2023-09-10 5:00 AM	6.99°C
2023-09-11 5:00 AM	4.53°C
2023-09-12 5:00 AM	5.24°C
2023-09-13 5:00 AM	4.13°C
2023-09-14 5:00 AM	9.07°C
2023-09-15 5:00 AM	8.81°C
2023-09-16 5:00 AM	9.83°C
2023-09-17 5:00 AM	4.7°C
2023-09-18 5:00 AM	5.23°C
2023-09-19 5:00 AM	4.03°C
2023-09-20 5:00 AM	3.97°C
2023-09-21 5:00 AM	6.3°C
2023-09-22 5:00 AM	7.25°C
2023-09-23 5:00 AM	4.7°C
2023-09-24 5:00 AM	8.98°C
2023-09-25 5:00 AM	4.22°C
2023-09-26 5:00 AM	8.76°C
2023-09-27 5:00 AM	6.91°C
2023-09-28 5:00 AM	7.63°C
2023-09-29 5:00 AM	6.7°C
2023-09-30 5:00 AM	9.21°C

THRESHOLD ALERTS

No Alert Events for selected date range.

CONNECTION ALERTS

CENTRAL TIME (US & CANADA)	MACHINE NAME	TYPE	RULE	LAST READING	ACTIVITY
2023-09-12 1:21 AM	Delp G040 +4	Connection	Delp G040 Connection Alert	Connected	Alert Cleared
			Notification:Email sent to Luigi Boccardi, Miranda Wright. Message:Delp G040 +4 has restored wireless connection to the Elemental Gateway. Alert Rule:Delp G040 Connection Alert		
			Message:Delp G040 +4 has restored wireless connection to the Elemental Gateway. Alert Rule:Delp G040 Connection Alert		
			Notification:Email sent to Luigi Boccardi, Miranda Wright. Message:Delp G040 +4 has lost wireless connection to the Elemental Gateway. Alert Rule:Delp G040 Connection Alert		
			Message:Delp G040 +4 has lost wireless connection to the Elemental Gateway. Alert Rule:Delp G040 Connection Alert		
2023-09-12 1:21 AM	Delp G040 +4	Connection	Copy of Connection Alert for All Element-A, Element-T and Gateways 4	Connected	Alert Cleared

			Notification:Email sent to Miranda Wright. Message:Delp G040 +4 has restored wireless connection to the Elemental Gateway. Alert Rule:Copy of Connection Alert for All Element-A, Element-T and Gateways 4		
			Message:Delp G040 +4 has restored wireless connection to the Elemental Gateway. Alert Rule:Copy of Connection Alert for All Element-A, Element-T and Gateways 4		

			Notification:Email sent to Miranda Wright. Message:Delp G040 +4 has lost wireless connection to the Elemental Gateway. Alert Rule:Copy of Connection Alert for All Element-A, Element-T and Gateways 4		
			Message:Delp G040 +4 has lost wireless connection to the Elemental Gateway. Alert Rule:Copy of Connection Alert for All Element-A, Element-T and Gateways 4		

POWER ALERTS

No Alert Events for selected date range.

ERROR ALERTS

No Alert Events for selected date range.

Delp G040 +4
for
Delp G040 +4

Oct 01, 2023 - Nov 01, 2023

Author: Miranda Wright
mwright15@kumc.edu

Review & approval records location:

Summary Report "Delp G040 +4" for Delp G040 +4

Oct 01, 2023 - Nov 01, 2023

MACHINE DETAILS


Serial Number: **6077715FD487**
Location: **Unknown**
Description: **6077715FD487**
Installation date:

EQUIPMENT DETAILS

Category: **Unknown**
Manufacturer:
Model:
Service Entered Date:

TEMPERATURE

AVG: **6.33 °C** | MIN: **2.93 °C** | MAX: **13.4 °C**



DATA LOGS

CENTRAL TIME (US & CANADA)	TEMPERATURE (°C)
2023-09-30 5:00 AM	8.17°C
2023-10-01 5:00 AM	4.43°C
2023-10-02 5:00 AM	6.43°C
2023-10-03 5:00 AM	4.73°C
2023-10-04 5:00 AM	8.17°C
2023-10-05 5:00 AM	4.38°C
2023-10-06 5:00 AM	7.54°C
2023-10-07 5:00 AM	4.37°C
2023-10-08 5:00 AM	5.79°C
2023-10-09 5:00 AM	6.73°C
2023-10-10 5:00 AM	4.95°C
2023-10-11 5:00 AM	7.35°C
2023-10-12 5:00 AM	7.8°C
2023-10-13 5:00 AM	8.52°C
2023-10-14 5:00 AM	6.41°C
2023-10-15 5:00 AM	5.66°C
2023-10-16 5:00 AM	5.04°C
2023-10-17 5:00 AM	6.01°C
2023-10-18 5:00 AM	5.85°C
2023-10-19 5:00 AM	6.35°C
2023-10-20 5:00 AM	5.47°C
2023-10-21 5:00 AM	7.54°C
2023-10-22 5:00 AM	8.42°C
2023-10-23 5:00 AM	5.14°C
2023-10-24 5:00 AM	6.1°C
2023-10-25 5:00 AM	7.38°C
2023-10-26 5:00 AM	8.13°C
2023-10-27 5:00 AM	4.16°C
2023-10-28 5:00 AM	4.6°C
2023-10-29 5:00 AM	8.86°C
2023-10-30 5:00 AM	3.61°C

CENTRAL TIME (US & CANADA)

TEMPERATURE (°C)

2023-10-31 5:00 AM

3.9°C

ALERTS

No Alert Events for selected date range.

Delp G040 +4
for
Delp G040 +4

Nov 01, 2023 - Dec 01, 2023

Author: Miranda Wright
mwright15@kumc.edu

Review & approval records location:

Summary Report "Delp G040 +4" for Delp G040 +4

Nov 01, 2023 - Dec 01, 2023

MACHINE DETAILS


Serial Number: **6077715FD487**
Location: **Unknown**
Description: **6077715FD487**
Installation date:

EQUIPMENT DETAILS

Category: **Unknown**
Manufacturer:
Model:
Service Entered Date:

TEMPERATURE

AVG: **6.76 °C** | MIN: **2.9 °C** | MAX: **11.92 °C**



DATA LOGS

CENTRAL TIME (US & CANADA)	TEMPERATURE (°C)
2023-10-31 6:00 AM	6.49°C
2023-11-01 6:00 AM	7.71°C
2023-11-02 6:00 AM	3.8°C
2023-11-03 6:00 AM	8.95°C
2023-11-04 6:00 AM	6.68°C
2023-11-05 6:00 AM	5.51°C
2023-11-06 6:00 AM	8.51°C
2023-11-07 6:00 AM	7.54°C
2023-11-08 6:00 AM	6.29°C
2023-11-09 6:00 AM	5.8°C
2023-11-10 6:00 AM	4.88°C
2023-11-11 6:00 AM	7.74°C
2023-11-12 6:00 AM	8.15°C
2023-11-13 6:00 AM	5.64°C
2023-11-14 6:00 AM	8.82°C
2023-11-15 6:00 AM	7.95°C
2023-11-16 6:00 AM	6.12°C
2023-11-17 6:00 AM	4.63°C
2023-11-18 6:00 AM	8°C
2023-11-19 6:00 AM	6.59°C
2023-11-20 6:00 AM	8.34°C
2023-11-21 6:00 AM	5.34°C
2023-11-22 6:00 AM	7.56°C
2023-11-23 6:00 AM	9.26°C
2023-11-24 6:00 AM	8.8°C
2023-11-25 6:00 AM	6.98°C
2023-11-26 6:00 AM	6.13°C
2023-11-27 6:00 AM	7.91°C
2023-11-28 6:00 AM	7.06°C
2023-11-29 6:00 AM	8.25°C
2023-11-30 6:00 AM	5.03°C

ALERTS

No Alert Events for selected date range.

Delp G040 +4
for
Delp G040 +4

Dec 01, 2023 - Jan 01, 2024

Author: Miranda Wright
mwright15@kumc.edu

Review & approval records location:

Summary Report "Delp G040 +4" for Delp G040 +4

Dec 01, 2023 - Jan 01, 2024

MACHINE DETAILS


Serial Number: **6077715FD487**
Location: **Unknown**
Description: **6077715FD487**
Installation date:

EQUIPMENT DETAILS

Category: **Unknown**
Manufacturer:
Model:
Service Entered Date:

TEMPERATURE

AVG: **6.59 °C** | MIN: **2.83 °C** | MAX: **13.89 °C**



DATA LOGS

CENTRAL TIME (US & CANADA)	TEMPERATURE (°C)
2023-11-30 6:00 AM	5.53°C
2023-12-01 6:00 AM	9.27°C
2023-12-02 6:00 AM	5.43°C
2023-12-03 6:00 AM	9.35°C
2023-12-04 6:00 AM	7.1°C
2023-12-05 6:00 AM	7.99°C
2023-12-06 6:00 AM	8.62°C
2023-12-07 6:00 AM	9.18°C
2023-12-08 6:00 AM	6.7°C
2023-12-09 6:00 AM	5.43°C
2023-12-10 6:00 AM	9.32°C
2023-12-11 6:00 AM	5.89°C
2023-12-12 6:00 AM	6.91°C
2023-12-13 6:00 AM	7.62°C
2023-12-14 6:00 AM	5.58°C
2023-12-15 6:00 AM	4.77°C
2023-12-16 6:00 AM	8.59°C
2023-12-17 6:00 AM	5.79°C
2023-12-18 6:00 AM	4.41°C
2023-12-19 6:00 AM	6.89°C
2023-12-20 6:00 AM	4.05°C
2023-12-21 6:00 AM	8.67°C
2023-12-22 6:00 AM	4.84°C
2023-12-23 6:00 AM	5.97°C
2023-12-24 6:00 AM	6.1°C
2023-12-25 6:00 AM	3.91°C
2023-12-26 6:00 AM	3.12°C
2023-12-27 6:00 AM	3.8°C
2023-12-28 6:00 AM	3.97°C
2023-12-29 6:00 AM	4.58°C
2023-12-30 6:00 AM	8.76°C
2023-12-31 6:00 AM	8.02°C

THRESHOLD ALERTS

CENTRAL TIME (US & CANADA)	MACHINE NAME	TYPE	RULE	LAST READING	LIMITS (H/L)	ACTIVITY
2023-12-12 2:22 PM	Delp G040 +4	Temperature	Copy of Threshold Alert for Element-T 4	8.44 °C	10.0/-100.0 °C	Alert Cleared
			Notification:Email and SMS sent to Miranda Wright.			
			Message:Delp G040 +4 is reporting Temperature of 8.44 °C, within the limit of -100.0 °C to 10.0 °C.			
			Alert Rule:Copy of Threshold Alert for Element-T 4			
			Message:Temperature Clear: 8.44 °C, within the limit of -100.0 °C to 10.0 °C			
			Alert Rule:Copy of Threshold Alert for Element-T 4			
			Notification:Email and SMS sent to Miranda Wright.			
			Message:Delp G040 +4 is reporting Temperature of 13.41 °C, still above the limit of 10.0 °C.			
			Alert Rule:Copy of Threshold Alert for Element-T 4			
			Message:Temperature Alert: 13.41 °C, above the limit of 10.0 °C			
			Alert Rule:Copy of Threshold Alert for Element-T 4			
			Notification:Email and SMS sent to Miranda Wright.			
			Message:Delp G040 +4 is reporting Temperature of 13.48 °C, still above the limit of 10.0 °C.			
			Alert Rule:Copy of Threshold Alert for Element-T 4			
			Message:Temperature Alert: 13.48 °C, above the limit of 10.0 °C			
			Alert Rule:Copy of Threshold Alert for Element-T 4			
			Notification:Email and SMS sent to Miranda Wright.			
			Message:Delp G040 +4 is reporting Temperature of 13.09 °C, above the limit of 10.0 °C.			
			Alert Rule:Copy of Threshold Alert for Element-T 4			
			Message:Temperature Alert: 13.09 °C, above the limit of 10.0 °C			
			Alert Rule:Copy of Threshold Alert for Element-T 4			

2023-12-12 2:22 PM	Delp G040 +4	Temperature	4 Degree Threshold Alert	8.42 °C	10.0/-100.0 °C	Alert Cleared
--------------------	--------------	-------------	---------------------------------	---------	----------------	---------------

CENTRAL TIME (US & CANADA)	MACHINE NAME	TYPE	RULE	LAST READING	LIMITS (H/L)	ACTIVITY
						Notification:Email sent to Miranda Wright.
	2023-12-12 2:22 PM					Message:Delp G040 +4 is reporting Temperature of 8.42 °C, within the limit of -100.0 °C to 10.0 °C.
						Alert Rule:4 Degree Threshold Alert
						Message:Temperature Clear: 8.42 °C, within the limit of -100.0 °C to 10.0 °C
	2023-12-12 2:22 PM					Alert Rule:4 Degree Threshold Alert
						Notification:Email sent to Miranda Wright.
	2023-12-12 2:10 PM					Message:Delp G040 +4 is reporting Temperature of 12.67 °C, still above the limit of 10.0 °C.
						Alert Rule:4 Degree Threshold Alert
						Message:Temperature Alert: 12.67 °C, above the limit of 10.0 °C
	2023-12-12 2:10 PM					Alert Rule:4 Degree Threshold Alert
						Notification:Email sent to Miranda Wright.
	2023-12-12 1:50 PM					Message:Delp G040 +4 is reporting Temperature of 12.97 °C, above the limit of 10.0 °C.
						Alert Rule:4 Degree Threshold Alert
						Message:Temperature Alert: 12.97 °C, above the limit of 10.0 °C
	2023-12-12 1:50 PM					Alert Rule:4 Degree Threshold Alert

CONNECTION ALERTS

No Alert Events for selected date range.

POWER ALERTS

No Alert Events for selected date range.

ERROR ALERTS

No Alert Events for selected date range.